

1. Name and trade name of the construction product:

Window trickle vents Ventair II TRDn

2. Type designation of the construction product:

Ventair II TRDn

3. Intended use(es):

For supplying air from the building surroundings to the rooms intended for continuous of temporary stay of people in residential buildings, collective dwellings (including hotels), public, office and utility buildings.

4. Name and registered address of the producer and production location:

BREVIS s.c. Marek Ćwikilewicz, Krzysztof Dzieża Cholerzyn 456
32-060 Liszki

5. National system applied for assessment and verification of constancy of performance:

System 3

6. National technical specification:

6a. National technical assessment:
ITB-KOT-2020/1575 wydanie 1

6b. Name of the notified certification body, notification number and certificate number:
INSTYTUT TECHNIKI BUDOWLANEJ 00-611 WARSZAWA ul. Filtrowa 1; AB 023

7. Declared performance(s):

Essential Characteristics of the construction product for the intended use(es)

Essential Characteristics of the construction product for the intended use(es)	Declared performance(s)	Notes	
Flow characteristic with $\Delta p = 10$ Pa	Fully open $q = 23,0 (\pm 2,30) [m^3/h]$ $\div 23,8 (\pm 2,38) [m^3/h]$	Fully closed $q = 5,4 (\pm 0,54) [m^3/h]$ $\div 5,7 (\pm 0,57) [m^3/h]$	
Resistance to penetration by rainwater	250 Pa		
Susceptibility to surface condensation	RH \geq 38%		
Acoustic performance	Trickle vent closed, [dB] $D_{new}(C;C_{tr}) = 40 (-2,-2)(\pm 2)$	Trickle vent open, [dB] $D_{new}(C;C_{tr}) = 34 (-1,-0)(\pm 2)$	

8. The performance of the product identified above is in conformity with all the performances declared in item 8.

This National Declaration of performance is issued pursuant to the Act dated 16 April 2004 on construction products, at the sole liability of the manufacturer.

Signed on the manufacturer's behalf:

Marek Ćwikilewicz