

**1. Name and trade name of the construction product:**

Window trickle vents Ventair TRDn Akustik

**2. Type designation of the construction product:**

Ventair TRDn Akustik

**3. Intended use(es):**

For supplying air from the building surroundings to the rooms intended for continuous of temporary stay of people in residential buildings, collective dwellings (including hotels), public, office and utility buildings.

**4. Name and registered address of the producer and production location:**

BREVIS s.c. Marek Ćwikilewicz, Krzysztof Dzieża Cholerzyn 456  
32-060 Liszki

**5. National system applied for assessment and verification of constancy of performance:**

System 3

**6. National technical specification:**

6a. National technical assessment:  
ITB-KOT-2018/0257 wydanie 3

6b. Name of the notified certification body, notification number and certificate number:  
INSTYTUT TECHNIKI BUDOWLANEJ 00-611 WARSZAWA ul. Filtrowa 1; AB 023

**7. Declared performance(s):**

Essential Characteristics of the construction product for the intended use(es)

Essential Characteristics of the construction product for the intended use(es)	Declared performance(s)	Notes
Flow characteristic with $\Delta p = 10 \text{ Pa}$	Fully open $q = 28,0 \text{ m}^3/\text{h}$ $\div 29,6 \text{ m}^3/\text{h}$	Fully closed $q = 7,1 \text{ m}^3/\text{h}$ $\div 7,9 \text{ m}^3/\text{h}$
Resistance to penetration by rainwater	450 Pa	
Susceptibility to surface condensation	$f_{Rsi} \geq 0,57$	
Acoustic performance	Trickle vent closed, [dB] $D_{new}(C;C_{tr}) = 47 (0,-3)$	Trickle vent open, [dB] $D_{new}(C;C_{tr}) = 42 (-1,-3)$

**8. The performance of the product identified above is in conformity with all the performances declared in item 8.**

This National Declaration of performance is issued pursuant to the Act dated 16 April 2004 on construction products, at the sole liability of the manufacturer.

Signed on the manufacturer's behalf: